

APA-1
07/04

**TRANSMITTAL SHEET FOR
NOTICE OF INTENDED ACTION**

Control No. _____ Department or Agency Alabama Liquefied Petroleum Gas Board
Rule No. 530-X-2-.17

Rule Title: FLAME EFFECTS BEFORE A PROXIMATE AUDIENCE.

X New _____ Amend _____ Repeal _____ Adopt by Reference _____

Would the absence of the proposed rule significantly harm or endanger the public health, welfare, or safety?

YES

Is there a reasonable relationship between the state's police power and the protection of the public health, safety, or welfare?

YES

Is there another, less restrictive method of regulation available that could adequately protect the public?

NO

Does the proposed rule have the effect of directly or indirectly increasing the costs of any goods or services involved and, if so, to what degree?

NO

Is the increase in cost, if any, more harmful to the public than the harm that might result from the absence of the proposed rule?

NO

Are all facets of the rulemaking process designed solely for the purpose of, and so they have, as their primary effect, the protection of the public?

YES

Does the proposed rule have an economic impact?

NO

If the proposed rule has an economic impact, the proposed rule is required to be accompanied by a fiscal note prepared in accordance with subsection (f) of Section 41-22-23, Code of Alabama 1975.

Certification of Authorized Official

I certify that the attached proposed rule has been proposed in full compliance with the requirements of Chapter 22, Title 41, Code of Alabama 1975, and that it conforms to all applicable filing requirements of the Administrative Procedure Division of the Legislative Reference Service.

Signature of certifying officer Mark Nelson

Date 04/18/2013

(DATE FILED)
(STAMP)

APA-2
07/04

ALABAMA LIQUEFIED PETROLEUM GAS BOARD

NOTICE OF INTENDED ACTION

RULE NO. & TITLE:

530-X-2-.17 "FLAME EFFECTS BEFORE A PROXIMATE AUDIENCE."

INTENDED ACTION: Adopt

SUBSTANCE OF PROPOSED ACTION: The intent of the proposed action is the adoption of a code standard for purposes of regulating flame effects commonly used in entertainment venues such as concerts.

TIME, PLACE, MANNER OF PRESENTING VIEWS: A public hearing will be held July 25, 2013 at 10:00 a.m., in the 2nd floor conference room located at the Alabama Liquefied Petroleum Gas Board, 777 South Lawrence Street, Montgomery, AL 36104. Copies of the proposed rule(s) can be obtained at www.lpgb.alabama.gov.


All interested parties may present their views in writing to the Administrator of the Alabama Liquefied Petroleum Gas Board, P.O. Box 1742, Montgomery, AL 36102-1742, (334-242-5649) Individuals desiring may also appear in person and present their views orally at the public hearing.

FINAL DATE FOR COMMENT AND COMPLETION OF NOTICE:

July 25, 2013 at the scheduled Public Hearing

CONTACT PERSON AT AGENCY:

Mark Nelson, Administrator
777 S. Lawrence St., Suite 100
Montgomery, AL 36104
Telephone: 334-242-5649
Fax: 334-240-2255



Mark Nelson, Administrator
Alabama Liquefied Petroleum Gas Board

530-X-2-.17 FLAME EFFECTS BEFORE A PROXIMATE AUDIENCE. The use of flame effects before an audience shall comply with the following:

- (a) Flame effect equipment shall comply with the current publication designated as NFPA 160, *Standard for the Use of Flame Effects Before an Audience*.
- (b) The maximum LP-gas capacity of individual cylinders used temporarily in buildings for flame effects shall be 20 lbs.
- (c) If more than one cylinder is located in the same room, the cylinders shall be separated by at least 20 feet. Where a separation of 20 feet is not practical, the authority having jurisdiction may approve a reduction of distances if cylinders are not subject to fire exposure or excessive radiant heat.
- (d) Cylinders shall not be installed or disconnected during the flame effect performance.
- (e) Storage of cylinders awaiting use shall comply with the current adopted edition of NFPA 58.

Author: Mark Nelson

Statutory Authority: Code of Ala. 1975, §9-17-105, as amended.

Adopted: _____ **Effective** _____