

APA-1  
11/96

**TRANSMITTAL SHEET FOR  
NOTICE OF INTENDED ACTION**

Control 335 Department or Agency Environmental Management  
Rule No. 335-7-6-15  
Rule Title: Lighting and Power Requirements

         New        X   Amend               Repeal               Adopt by Reference

Would the absence of the proposed rule significantly harm or endanger the public health, welfare, or safety?          YES

Is there a reasonable relationship between the state's police power and the protection of the public health, safety, or welfare?          YES

Is there another, less restrictive method of regulation available that could adequately protect the public?          NO

Does the proposed rule have the effect of directly or indirectly increasing the costs of any goods or services involved and, if so, to what degree?          NO

Is the increase in cost, if any, more harmful to the public than the harm that might result from the absence of the proposed rule?          NO

Are all facets of the rulemaking process designed solely for the purpose of, and so they have, as their primary effect, the protection of the public?          YES

\*\*\*\*\*  
Does the proposed rule have an economic impact?          NO

If the proposed rule has an economic impact, the proposed rule is required to be accompanied by a fiscal note prepared in accordance with subsection (f) of section 41-22-23, Code of Alabama 1975.


\*\*\*\*\*  
Certification of Authorized Official

I certify that the attached proposed rule has been proposed in full compliance with the requirements of Chapter 22, Title 41, Code of Alabama 1975, and that it conforms to all applicable filing requirements of the Administrative Procedure Division of the Legislative Reference Service.

Signature of certifying officer *Nancy Elliott*

Date March 20, 2012

Date Filed



APA-2  
11/96

**DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
WATER DIVISION**

**NOTICE OF INTENDED ACTION**

**AGENCY NAME:** DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

**RULE NO. & TITLE:** 335-7-6-.03 Source Selection Report (Amend)  
335-7-6-.04 Treatment Requirements (Amend)  
335-7-6-.05 Surface Water Intake Structures (Amend)  
335-7-6-.15 Lighting and Power Requirements (Amend)


**INTENDED ACTION:** The Alabama Department of Environmental Management proposes to revise division 335-7, Public Water Supply.

**SUBSTANCE OR PROPOSED ACTION:** Revisions to rules 335-7-6-.03, 335-7-6-.04(b), 335-7-6-.05, and 335-7-6-.15 are being proposed to require electronic submittal of reports and to make technical changes.

**TIME, PLACE, MANNER OF PRESENTING VIEWS:** Comments may be submitted in writing or orally at a public hearing to be held May 2, 2012, at 10:00 a.m. in the Main Hearing Room at the ADEM Central Office located at 1400 Coliseum Blvd., Montgomery, AL 36110.

**FINAL DATE FOR COMMENT AND COMPLETION OF NOTICE:** May 4, 2012 at 5:00 p.m.

**CONTACT PERSON AT AGENCY:** George M. Cox, Section Chief  
Groundwater Section [334/271-7778]

  
\_\_\_\_\_  
Lance R. Lefleur  
Director

**335-7-6-.15 Lighting and Power Requirements.**

(1) Proper illumination shall be available to allow evaluation of treatment processes at the water treatment plant at all times.

(2) New community treatment facilities permitted for construction after December 31, 2005 shall have sufficient auxiliary power capacity available to operate essential equipment at the plant.

(3) All community surface water treatment facilities shall have sufficient auxiliary power available to operate essential equipment no later than December 31, 2010.

(a) Essential equipment includes, but is not limited to, raw water pumps, laboratory testing equipment, monitoring equipment, and high service pumps needed to meet expected customer demand for finished drinking water during emergency conditions.

(b) If a water system owns more than one water treatment facility, it can designate one facility as the primary facility and this facility must meet the requirements of this paragraph and be capable of supplying the entire distribution system during emergency conditions.

(c) The auxiliary power requirement can be met by having an on-site generator or an equivalent design approved by the Department.

**Author:** Edgar K. Hughes.

**Statutory Authority:** Code of Alabama 1975, §§ 22-23-33, 22-23-49, 22-22A-5, 22-22A-6.

**History:** Repealed: November 7, 2005; Readopted: December 12, 2005.

**Amended:** January 18, 2011; XXXXX, 2012.